
EXPERIENCIAS, DIFICULTADES Y VENTAJAS EN EL ESTABLECIMIENTO DE HUMEDALES CONSTRUIDOS EN PAÍSES EN VIAS DE DESARROLLO.


Arias C. A. & Brix H.



carlo

TRATAMIENTOS DE AGUAS EN PAISES EN VIA DE DESARROLLO

En Malaysia 89 de las 91 plantas de tratamiento de aguas residuales convencionales no funcionan o producen efluentes que no cumplen las normas .
Situación similar en India, Tailandia, México, Colombia, Perú, Vietnam, etc.



Sistemas altamente tecnificados instalados en países en vías de desarrollo tienen alta probabilidad de fallar.

Y FALLAN!

No hay alcantarillados adecuados

Aguas residuales diluidas

Operarios no calificados

Falta de recursos económicos y humanos

Descuido en rutinas de operación y mantenimiento

Prioridades políticas locales.





PLANTA DE TRATAMIENTO DE LA CIUDAD DE

.....



INFRASTRUCTURA UTIL



Características para la selección de soluciones

Construcción y mantenimiento a costos asequibles

Tratamientos basados en procesos naturales

Soluciones in-situ y descentralizadas


Bajos costos de construcción

Bajos costos de operación y mantenimiento

Poca exigencia de mantenimiento.

Sistemas de tratamiento que cumplan con las exigencias de descarga

Sistemas que ofrezcan potencial para recuperar recursos (agua, biomasa, energía).



Humedales en países en vías desarrollo (tropicales subtropicales?)

Como diseñarlos?

Se carece de información básica!

Bases de datos?

Constantes cinéticas?

Plantas?

Materiales?

Modelos numéricos













AARHUS
UNIVERSITET



14. MAJ 2016

ARIAS Y BRIX









Como construirlos

Materiales adecuados

Capacidad constructiva

Tecnicas constructivas

Diseños adecuados

Control de calidad



COMO CONSTRUIRLOS

Firmas y constructores sin experiencia suficiente







Diferencias culturales

- Distancia en el poder
- Incertidumbre
- Género
- Individualismo
- Planeación a largo plazo
- Manejos económicos

Ventajas

Receptividad


Innovación

Reacciones cinéticas diferentes

Materiales innovadores

Prácticas locales






Aligarh Muslim University, (AMU, Aligarh)

Kalyani University, (KLY, Kalyani)

Indira Gandhi National Tribal University, (IGNTU, Amarkantak)


AMU AD-CW pilot plant construction




Primary treatment
(Anaerobic digestion)

Secondary treatment
(Constructed wetlands)

Solar-driven disinfection



UASB System





Vertical Flow and
Horizontal Flow
Sub-Surface CWs





AO










Design parameters for UASB

Dimensions (length/width/depth)	3.54/ 3.04/ 4.87	m
Volume	51.13	m ³
Sludge Bed Concentration	65 - 75	Kg TSS/m ³
Upflow Velocity at Avg. Flow	0.52-0.54	m/h
Min. hydraulic retention time (HRT)	7.0	hrs.
SRT at design temp.	35-40	days
VSS destruction in Reactor	50	%





AMU AD-CW: West and East VFCWs construction



AMU AD-CW: West and East VFCWs construction



AMU AD-CW: West and East VFCWs construction



AMU AD-CW: West and East HFCWs construction




AMU AD-CW: Planting of the beds and final effluent




Solar-driven disinfection systems




AMU AD-CW - steady state condition




AMU AD-CW - steady state condition



AMU AD-CW - steady state condition



AMU AD-CW - steady state condition




Effluent polishing
gravel bed

Solar driven disinfection



LATERAL VIEW



KALYANI site

Background Objectives

Disinfection by:

1. Natural Filtration Systems


- a. Bank Filtration
- b. Soil Aquifer Treatment

2. Chemical Free Solar Driven Disinfection Systems

- a. Solar AO
- b. Solar UV

3. Determine overall treatment performance for safe reuse of treated wastewater

Kalyani wastewater treatment system



Kalyani University Site



Maturation Ponds at Kalyani Site




Kalyani Wastewater Stabilization Ponds




Bank Filtration

- River bank filtration commonly applied for drinking water treatment




Solar AO System


- AO – Anodic Oxidation
- Up to 20 m³/d
- Solar pumping
- Prefiltration with automatic backwash
- Online water quality control by ORP
- Chlorine production 0,3 – 10 mg/L



Chlorine production with solar Anodic Oxidation (AO)



- Natural mineral content of water is sufficient
- Reliable disinfection without any chemicals





Technologies SolarSpring – SolarUV

10 m³/day SolarUV (AMU)


3 m³/day SolarUV (Kalyani)

- Power supply – 800 Wp
- Pre-filtration with automated back flush function + cartridge filter
- Disinfection quality monitoring by UV sensors
- Water storage disinfection by UV
- Data acquisition and remote access system for quality control and improved maintenance



Hydro-geological survey

- Drilling of sampling wells
- Determination of water tables
- Establishment of hydrogeological triangle



Hydrogeological survey

- Identification of Soil profile and filtration properties



Drilling of BF Wells



Site Construction

- Construction of solar disinfection system building



Installation of Solar Driven Disinfection Systems




Installation of Solar Driven Disinfection Systems




Finalized BF Site



Solar UV system




Solar AO System



Solar driven disinfection systems




First measurements of Total Coliforms - KALYANI




Refurbishment of Ponds



Soil aquifer treatment (SAT) - 2015 (intermittently)




Soil Aquifer Treatment





Schematic view of the soil aquifer treatment process (Miotlinski et al., 2010).

SAT well and aeration




First results




Sampling Plan Kalyani Site

Solar AO System




Solar UV System




Parameters	Times per month
Turbidity, TDS	8
EC, pH, DO, ORP, Temp	8
Hardness	4
Iron	8
Manganese	8
Chloride	1
Chlorine (only AO)	8
Nitrogen, Nitrate, Nitrate, Ammonia	4
Phosphorous	4
COD, BOD	4
E.Coli and total coliform	4

In total 8 Sampling Points


Total Coliform removal AO System




Total Coliform removal UV System



E.coli removal AO System



E.coli removal UV System



Comparison AO and UV System


Total coliforms

Parameter	Inlet (well)	Outlet AO	Outlet UV (extra)
Mean (CFU/100mL)	6.3 ⁺³	7.2 ⁺¹	2.0 ³
SD (CFU/100mL)	8.6 ⁺³	8.9 ⁺¹	3.1 ³
Min (CFU/100mL)	0	0	1
Max (CFU/100mL)	3.2 ⁺⁴	2.9 ⁺²	1.1 ⁴
N	29	18	18
% removal		99%	69%
log removal		1.9	0.5


E.coli

Parameter	Inlet (well)	Outlet AO	Outlet UV (extra)
Mean (CFU/100mL)	1.4 ⁺²	0	3.5 ⁺¹
SD (CFU/100mL)	2.5 ⁺²	0	5.9 ⁺¹
Min (CFU/100mL)	0	0	0
Max (CFU/100mL)	9.7 ⁺²	0	2.0 ⁺²
n	35	25	3.5 ⁺¹
% removal		100%	75 %
log removal		2.2	0.6

Total iron removal



Solar AO System



Solar UV System

Parameter	Inlet (well)	Outlet AO	Outlet UV
Mean (mg/L)	7.7	0.02	0.04
SD (mg/L)	1.4	0.03	0.03
Min (mg/L)	6.3	0.01	0.01
Max (mg/L)	11.9	0.10	0.11
n	12	18	10
% removal		99.7%	99.5%



Treatment Performance

Turbidity

Parameter	Inlet (well)	Outlet AO	Outlet UV
Mean (NTU)	72.1	0.4	3
SD (NTU)	13.8	0.1	2
Min (NTU)	51.3	0.2	1
Max (NTU)	98.3	0.5	8
N	19.0	7	12
% removal		99%	96%

TSS

Parameter	Inlet (well)	Outlet AO	Outlet UV
Mean (mg/L)	0.32	0.12	0.12
SD (mg/L)	0.17	0.10	0.09
Min (mg/L)	0.03	0.01	0.03
Max (mg/L)	0.66	0.34	0.30
n	14	14	7
% removal		64%	63%

Treatment Performance

Ammonium nitrogen

Parameter	Inlet (well)	Outlet AO	Outlet UV
Mean (mg/L)	17.37	11.79	14.17
SD (mg/L)	7.28	6.68	8.61
Min (mg/L)	4.12	0.73	2.66
Max (mg/L)	55	45.7	50
N	38	38	25
% removal		32%	18%

Orthophosphate phosphorus

Parameter	Inlet (well)	Outlet AO	Outlet UV
Mean (mg/L)	0.90	0.10	0.41
SD (mg/L)	0.58	0.14	0.30
Min (mg/L)	0.14	<LOD	<LOD
Max (mg/L)	2.80	0.83	0.92
n	33	33	19
% removal		89%	54%

Potential reuse applications

¹[SCHEDULE - VI]
(See rule 3A)

GENERAL STANDARDS FOR DISCHARGE OF ENVIRONMENTAL POLLUTANTS PART-A : EFFLUENTS

S. No.	Parameter	Standards			
		Inland surface water	Public Sewers	Land for irrigation	Marine coastal areas
1	2	3			
		(a)	(b)	(c)	(d)
1.	Colour and odour	See 6 of Annexure-I	--	See 6 of Annexure-I	See 6 of Annexure-I
2.	Suspended solids mg/l, Max.	100	600	200	(a) For process waste water-100 (b) For cooling water effluent 10 percent above total suspended matter of influent.
3.	Particulate size of suspended solids	Shall pass 850 micron IS Sieve	--	--	(a) Floatable solids, max. 3 mm. (b) Settleable solids, max. 850 microns.
² 4.	***	*	--	***	--
5.	pH Value	5.5 to 9.0	5.5 to 9.0	5.5 to 9.0	5.5 to 9.0
6.	Temperature	shall not exceed 5°C above the receiving water temperature	--	--	shall not exceed 5°C above the receiving water temperature

¹ Schedule VI inserted by Rule 2(d) of the Environment (Protection) Second Amendment Rules, 1993 notified vide G.S.R. 422(E) dated 19.05.1993, published in the Gazette No. 174 dated 19.05.1993.

² Omitted by Rule 2(d)(i) of the Environment (Protection) Third Amendment Rules, 1993 vide Notification No.G.S.R.801(E), dated 31.12.1993.



Results at Kalyani

- Good disinfection performance
 - Sufficient for agricultural reuse
 - Robust and reliable operation of systems
 - Development of marketable products in India
 - New future research topics
 - Arsenic removal
 - Ammonium removal
 - Performing bank filtration
-

IGNTU site

Objectives at IGNTU site

- To provide sustainable sanitation by producing an effluent of sufficient quality to be reused in landscape and agriculture irrigation, industrial processes and other uses for humans
-

IGNTU - two Sites

Lalpur Village

- A solar powered anodic oxidation system installed in the village of Lalpur
- A small infrastructure (with basic laboratory equipment) were built for the system, solar panels and water storage tank.
- An adequate water quality control sensor setting and online monitoring unit were tested, evaluated and optimized.
- From the tank, the water was distributed to the village people using simple tap points



IGNTU Campus

- The quality of treated sewage vary to great extent
- To maintain the quality of treated sewage a gravel bed of 10.5 m X 3.5m was constructed
- The treated sewage is pre-filtered through this bed
- Followed by Zeolite media filtration and disinfection through internally produced chlorine



IGNTU – Field Survey

Parameter	Location 1 Borehole at Staff Quarter IGNTU	Location 2 borehole girls hostel IGNTU	Location 3 Village Bijauri Deep Well 1	Location 4 Bijauri Hand dug well (old man)	Location 5 Pamara Iron well	Location 6 Lalpur
Temperature [°C]	27,4	27,3	29,5	25,5	25,9	27,1
pH	6,89	6,62	8,1	7,53	6,89	7,9
Conductivity [μ S/cm]	301	318	342	245	296	301
Total Fe [mg/L]	0,14	< 0,02	0,04	0,12	10,1	< 0,02
Manganese [mg/L]					0,22	< 0,01
Chloride [mg/L]	5,4	5,2	33,5	25,5	20,5	59
Depth	200-300	200 - 300	~ 300	16	n.d.	180



Lalpur: Construction of solar driven water station

- Water tower and small lab (9 m²) construction at Lalpur village
- Drilling 90 m deep well constructed for submersible solar pump




Construction of solar driven water supply station

- AO system installation:
 - solar panels
 - battery bank
 - pipeline connections
 - pre filtration
 - AO unit implementation
- Water distribution into the village




Campus Unit for STP effluent disinfection



Construction of Planted Gravel Bed Filter



Installation of solar driven disinfection system



Inlet chamber



Planted Gravel Bed



Reuse of treated water for irrigation



Reuse of treated water for irrigation



Campus irrigation



Seedlings field



Performance Evaluation





Parameters currently analyzed

S. No.	Parameter		Parameter
1	pH	13	BOD ₅ (mg/L)
2	Temperature (°C)	14	COD (mg/L)
3	Conductivity (µs/cm)	15	Total coliforms (MPN/100mL)
4	TDS (mg/L)	16	Fecal coliforms (MPN/100mL)
5	ORP (mV)	17	<i>E. Coli</i> (MPN/100mL)
6	Alkalinity (mg/L)	18	<i>Enterococcus fecalis</i>
7	Acidity (mg/L)	19	<i>Clostridium</i>
8	Hardness (mg/L)	20	<i>Salmonella</i>
9	Calcium (mg/L)	21	<i>Enterococcus</i>
10	Magnesium (mg/L)	22	<i>Clostridium perfringens</i>
11	DO (mg/L)	23	<i>Pseudomonas aeurogenosa</i>
12	Nitrate	24	Orthophosphate

Results at IGNTU site


Parameters	Inlet Chamber	After Gravel Bed	After zeolite filter	After AO Treatment
temp °C	21.7	20.8	21.6	22.9
pH	8.3	8.55	8.83	8.2
DO (mg/L)	3	3.8	5.6	11
Acidity (mg/L)	90	56	4	6
Alkalinity (mg/L)	66	182	190	172
Hardness (mg/L)	106	70	417	34
ORP (mV)	210	230	388	431
EC (uS/cm)	1312	738	760	732
TDS (mg/L)	656	376	380	367
BOD ₅ (mg/L)	48	26	18	10

Water quality during disinfection




Water quality during disinfection



Alkalinity (mg/l)





Acidity (mg/l)



Water quality during disinfection



Chloride and residual chlorine in final treated water



Muchas gracias por su atención

